

<div> <div>Select</div> <div>Filter</div> <div>Statistics</div> <div>Answer Episodes</div> <div>Re-generate Episodes</div> <div>Legend</div> <div>Help</div> </div>								
<div> <div>Page#</div> <div>1</div> <div>2</div> <div>3</div> <div>4</div> <div>5</div> <div>6</div> <div>7</div> <div>8</div> <div>9</div> <div>10</div> <div>...</div> </div>								
<input type="checkbox"/> All	Episode Name	Start Time	End Time	Type	Real Value	Value Limit	Status	By
<input type="checkbox"/>	Pa Low Temp	03/14/2003 13:58:00	03/14/2003 13:58:00	Under Limit	1752.3	1753	Ans	2
<input type="checkbox"/>	CCDC Opacity	03/14/2003 13:24:00	03/14/2003 13:29:00	Over Limit	14.8	14.7	Ans	1
<input type="checkbox"/>	20 Minute SO2_Corrected Over Limit	03/14/2003 13:20:00	03/14/2003 13:39:00	Over Limit	863.5	862.5	Ans	MCDADETT
<input type="checkbox"/>	Pa Low Temp	03/14/2003 13:19:00	03/14/2003 13:23:00	Invalid	0	0	Ans	2
<input type="checkbox"/>	CCDC Opacity	03/14/2003 13:18:00	03/14/2003 13:23:00	Invalid	0	0	Ans	2
<input type="checkbox"/>	edtest Downtime	03/14/2003 13:15:00	03/14/2003 13:29:00	Invalid	0	0	Ans	5
<input type="checkbox"/>	Pa Low Temp	03/14/2003 13:00:00	03/14/2003 13:00:00	Under Limit	1752.5	1753	Ans	2
<input type="checkbox"/>	CCDC Opacity	03/14/2003 12:42:00	03/14/2003 12:47:00	Over Limit	14.8	14.7	Ans	2
<input type="checkbox"/>	20 Minute SO2_Corrected Over Limit	03/14/2003 12:40:00	03/14/2003 12:59:00	Over Limit	862.7	862.5	Ans	MCDADETT
<input type="checkbox"/>	Pa Low Temp	03/14/2003 11:12:00	03/14/2003 11:12:00	Under Limit	1751.8	1753	Ans	2
<input type="checkbox"/>	20 Minute SO2_Corrected Over Limit	03/14/2003 10:20:00	03/14/2003 10:39:00	Over Limit	862.8	862.5	Ans	2
<input type="checkbox"/>	20 Minute SO2_Corrected Over Limit	03/14/2003 10:00:00	03/14/2003 10:19:00	Over Limit	863.6	862.5	Ans	2
<input type="checkbox"/>	Pa Low Temp	03/14/2003 08:52:00	03/14/2003 08:52:00	Under Limit	1751.8	1753	Ans	2
<input type="checkbox"/>	20 Minute SO2_Corrected Over Limit	03/14/2003 08:00:00	03/14/2003 08:19:00	Over Limit	862.7	862.5	Ans	2
<input type="checkbox"/>	CCDC Opacity	03/14/2003 07:42:00	03/14/2003 07:47:00	Over Limit	14.8	14.7	Ans	2
<input type="checkbox"/>	Pa Low Temp	03/14/2003 07:35:00	03/14/2003 07:36:00	Invalid	0	0	Ans	2

FIG. 15

Answer Selected Episodes - Microsoft Internet Explorer

Data for Selected Episodes

Episode Name	Start Time	End Time	Type	Real Value	Value Limit	Status	Reason Code	Modification Time	Who_id
20 Minute SO2_Corrected Over Limit	03/14/2003 13:20:00	03/14/2003 13:39:00	Over Limit	863.5	862.5	Ans	16	10/28/2003 06:57:00	2

Answer all with this Reason

16: Pri. Analyzer Malfunction

Using this Corrective Action

Recalibrated Analyzer(s)

Ok

Cancel

FIG. 16